



SECTION VIEW

NOTES:

- | | |
|---|--|
| <p>① NO. 5½ BOX, LID LABELED "IRRIGATION", CONCRETE FORNI OR EQUAL.</p> <p>② INSTALL NEW 6" x 6" P.C.C. COLLAR.</p> <p>③ PROVIDE 6' OF CONDUCTOR SLACK - INSIDE OF HANDHOLE, NEATLY COILED. CONDUCTOR SIZE PER SPEC'S.</p> <p>④ WATERPROOF 1 POLE FUSED SPLICE. CONNECT WITH 5 AMP FUSE, PER SPEC'S.</p> <p>⑤ 1/4" GALVANIZED WIRE MESH.</p> <p>⑥ HOLD DOWN BOLT.</p> <p>⑦ FROM PG&E OR POWER SOURCE.</p> | <p>⑧ TO LOAD.</p> <p>⑨ 5/8" COPPER CLAD GROUND ROD, LENGTH AS REQUIRED.</p> <p>⑩ 3/4" DRAIN ROCK 6" DEPTH.</p> <p>⑪ SEAL CONDUIT WITH ELECTRICIANS PUTTY.</p> <p>⑫ FINISH GRADE.</p> <p>⑬ SET TOP OF BOX ABOVE FINISH GRADE: 1" IN SOD, 2" IN PLANTER OR DECOMPOSED GRANITE.</p> <p>⑭ (3) COMMON BRICKS FOR SUPPORT.</p> |
|---|--|

REVISION	BY	DATE	APP. BY COUNCIL

CITY OF CHICO

STANDARD PLAN

DRAWN BY: GL DATE: 10/06
 CHECKED BY: DB SCALE: NONE
 APPROVED: *[Signature]*
 DIRECTOR OF ENGINEERING

**CONTROLLER SERVICE
PULL BOX**

NO.
LS-13

SHEET 1 OF 1