



SECTION VIEW

NOTES:

- ① AIR/VACUUM RELIEF VALVE GEOFLOW OR EQUAL.
- ② FINISH GRADE.
- ③ SET TOP OF BOX ABOVE FINISH GRADE: 1" IN SOD, 2" IN PLANTER OR DECOMPOSED GRANITE.
- ④ 10" ROUND VALVE BOX CARSON #910 OR EQUAL.
- ⑤ 1/2" PVC COUPLING (TxT).
- ⑥ 1/2" SCHEDULE 80 NIPPLE (LENGTH AS REQUIRED).
- ⑦ PEA GRAVEL, 6" DEPTH.
- ⑧ POLY TUBING, CONNECT TO NIPPLE WITH COMPRESSION TEE S x S x C.
- ⑨ (3) COMMON BRICKS FOR SUPPORT.
- ⑩ 1/4" GALVANIZED WIRE MESH.

REVISION	BY	DATE	APP. BY COUNCIL

CITY OF CHICO

STANDARD PLAN

DRAWN BY: GL DATE: 11/06
 CHECKED BY: DB SCALE: NONE
 APPROVED: [Signature]
 DIRECTOR OF ENGINEERING

AIR/VACUUM RELIEF VALVE

NO.
LS-22

SHEET 1 OF 1