

(Ord. 2358 §22)

**Table 6-38 Emergency Response Network Standards**

	<b>Chico Municipal Code Title 18R TND Standard #</b>	<b>Thoroughfare Type</b>	<b>Private Lot Frontage on Thoroughfare Segment</b>	<b>Maximum Distance to Primary or Secondary ERN</b>	<b>Maximum Block Length</b>	<b>Intersection Detailed for Fire Department Vehicle</b>	<b>Length of Curb Bulb Out in Parking Lane at Intersections</b>
<b>Primary Emergency Response Network</b>	TN-2	Blvd with side drive and bike lane Free Movement	Alley Required	n/a	660'	Yes	20'
	TN-3	Blvd with bike lanes Free Movement	Alley Required	n/a	660'	Yes	20'
	TN-4	36' Commercial Street Free Movement	Alley Required	n/a	660'	Yes	20'
<b>Secondary Emergency Response Network</b>	TN-5	32' Interior Street Free Movement	Alley Required	n/a	660'	Yes Curb bulb at top of tee intersection	30'
	TN-6	27' Interior Street Free Movement	Alley Required	n/a	660'	Yes Curb bulb at top of tee intersection	30'
	TN-7	27' Drive at Greenway Free Movement	Alley Required	n/a	660'	Yes Curb bulb at top of tee intersection	30'
<b>Off-Network Thoroughfare</b>	TN-8	26' Interior Street One Way	Alley Required. Buildings addressing off-network streets farther than 150' from the ERN require NFPA 13 BR fire sprinklers.	500'	400'	Yes Curb bulb at top of tee intersection	30'

**Table 6-38 Emergency Response Network Standards (continued)**

	Chico Municipal Code Title 18R TND Street Standard #	Thoroughfare Type	Private Lot Frontage on Thoroughfare Segment	Maximum Distance to Primary or Secondary ERN	Maximum Block Length	Intersection Detailed for Fire Department Vehicle	Length of Curb Bulb Out in Parking Lane at Intersections
Off-Network Thoroughfares	TN-9	19' Interior Street One Way	Alley Required. Buildings addressing off-network streets farther than 150' from the ERN require NFPA 13 BR fire sprinklers.	500'	300'	Yes Curb bulb at top of tee intersection	30'
	TN-10	19' One-Way Interior Street Free Movement at Green or Square	Alley Required. Building addressing off-network streets farther than 150' from the ERN require NFPA 13 BR fire sprinklers.	500'	300'	Yes Curb bulb at top of tee intersection	30'
	TN-12	20' ROW Alley	Accessory unit allowed if fire hose is provided through front of lot. If access is only from the alley and the building is further than 150' from nearest ERN street, NFPA 13 fire sprinklers required in accessory unit.	n/a	n/a	No	n/a
	TN-14	Mid-Block Passage	Buildings greater than 150' from curb of the nearest ERN street require NFPA 13 fire sprinklers.	n/a	n/a	No	n/a
	n/a	Bungalow Court	Buildings greater than 150' from curb of the nearest ERN street require NFPA 13 fire sprinklers.	n/a	n/a	No	n/a
	n/a	Walkway for an Engaged Green or Plaza	Buildings greater than 150' from curb of the nearest ERN street require NFPA 13 fire sprinklers.	n/a	n/a	No	n/a
	n/a						

**19.90.040 Street and Streetscape Standards.**