

<i>Street Type</i>	<i>Use</i>	<i>Pavement Width</i>	<i>Base</i>	<i>Asphalt Pavement</i>	<i>Concrete Pavement</i>	<i>Full Depth Asphalt</i>
Local Street	Single Family	28 feet	10" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 2" Item 448 Asphalt Intermediate Course, Type 2	7 inches	4 - 6 inches
	Multi-Family	30 feet	10" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 2" Item 448 Asphalt Intermediate Course, Type 2	7 inches	4 - 6 inches
	Business, Service and Industrial	32 feet	10" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 3" Item 448 Asphalt Intermediate Course, Type 2	9 inches	6 - 9 inches
Collector Street	Single Family	28 feet	10" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 2" Item 448 Asphalt Intermediate Course, Type 2	7 inches	5 - 9 inches
	Multi-Family	32 feet	10" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 2" Item 448 Asphalt Intermediate Course, Type 2	7 inches	5 - 9 inches
	Business, Service and Industrial	36 feet	12" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 3" Item 448 Asphalt Intermediate Course, Type 2	9 inches	8 - 11 inches
Arterial Street	Single and Multi-Family	36 feet	10" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 3" Item 448 Asphalt Intermediate Course, Type 2	7 inches	6 - 11 inches
	Business, Service and Industrial	48 feet	12" Item 304 Aggregate Base	1½" Item 448 Asphalt Surface Course, Type 1 1½" Item 448 Asphalt Intermediate Course, Type 1 2" Item 448 Asphalt Intermediate Course, Type 2	9 inches	8 - 11 inches

NOTES:

1. All Item Numbers refer to the Ohio Department of Transportation (ODOT) Construction and Materials Specifications (CMS) Latest Edition.
2. Pavement designs shall be approved by the city, some projects may require additional pavement thickness.
3. All full depth asphalt designs must include a minimum of 4" ODOT Item 304 Aggregate Base.
4. Pavement width shall be measured face to face of curbs.
5. All concrete pavement shall be in accordance with ODOT CMS Item 451 Reinforced Concrete Pavement.
6. Base for concrete pavement surface may be reduced to 6" ODOT Item 304 Aggregate Base.

